

Materialprüfungsamt Nordrhein-Westfalen - 44285 Dortmund

DORMA Deutschland GmbH
DORMA Platz 1
58256 Ennepetal
Germany

Ihr Zeichen: P.S.
Ihre Nachricht vom : 16.05.2014
Unser Zeichen: 120594296-01
Durchwahl: 493
Direktfax: +49 (0)231 4502 586
E-Mail: meinks@mpanrw.de
Datum: 28.08.2014

Extension of validity of a test certificate.

Dear Ladies and Gentlemen,

Concerning the results of the initial type test carried out with the controlled door closing device DORMA BTS 75V EN 1-4 you applied for the extension of validity of test certificate no. 120594296-02.

The tests have been carried out on the base of the DIN EN 1154:1997-05 (see test report no. 120594296-01).

Today the DIN EN 1154: 2003-04 is valid.

The changes which have been made within the revision of this version of the DIN EN 1154 have no influence to the results and the classification of the door closer DORMA BTS 75V EN 1-4.

You have also assured that the door closer was not modified since the initial type test.

Therefore the validity of the test certificate no. 120594296-02 is extended up to July, 1st 2019.

Best regards
By order



H. Jansen
Head of test laboratory



Th. Meinks
Technischer Amtsinspektor

TEST CERTIFICATE No. 12 0594 2 96-02

Contracting Party

DORMA GmbH & Co. KG
P.O. Box 40 09
D-58247 Ennepetal / Germany

Assignment

Testing of controlled door closing devices (door closer) in accordance with DIN EN 1154: 1997-05 (Ref. No. EN 1154: 1996 D).

Description of Samples

Single and double action floor concealed door closer in accordance with illustrations C.1.4a and C.1.4b of DIN EN 1154,
floor spring „DORMA BTS 75V EN 1-4“.
Installation corresponding with the drawings, appendix 1.

Description of the Test and Test Results

See Test Report No. 12 0594 2 96-01.

Evaluation of the Test Results

The door closer „DORMA BTS 75V EN 1-4“ fulfils the requirements of the DIN EN 1154.
It is classified as follows in accordance with sec. 4 of DIN EN 1154:

3	8	4 1	1	1	4**)
---	---	--------	---	---	------

***) An evaluation of the appearance of the test piece was not conducted, see 6.2 of the DIN EN 1670: 1998-12.

Instructions

The manufacturer is to refer in the documentation for assembly and adjustment of the product that the door closer may not be adjusted to door closer power size less than 3 in use on fire/smoke door assemblies.

Dortmund, December 7th, 1999

Jansen

Dipl.-Ing. H. Jansen
Regierungsbauamtsrat



This is the English version of „Prüfzeugnis Nr. 12 0594 2 96-02“.

The validity of this certificate expires on July 1st, 2004.

The results of the tests are exclusively in relation to the test piece indicated above. Test certificates may without the consent of the MPA NRW only be published or reproduced in accordance with their unaltered form and content. The abbreviated reproduction of a test certificate is only permissible with the consent of the MPA NRW. This test certificate comprises 1 page and 1 appendix.

