

Materialprüfungsamt Nordrhein-Westfalen - 44285 Dortmund

DORMA Holding GmbH + Co. KGaA
DORMA Platz 1
58256 Ennepetal
Germany

Ihr Zeichen: Vogel
Ihre Nachricht vom : 27.08.2010
Unser Zeichen: 120002116.51
Durchwahl: 493
Direktfax: +49 (0)231 4502 586
E-Mail: meinks@mpanrw.de
Datum: 13.10.2010

Extension of validity of a test certificate.

Dear Mr. Vogel,

Concerning the results of the initial type test carried out with the controlled door closing device „Dorma TS 90 Impulse EN 3/4“ you applied for the extension of validity of test certificate no. 120002116.51-03.

The tests have been carried out on the base of the DIN EN 1154: 2003-04 (see test report no. 120002116.51-01). Today the DIN EN 1154: 2003-04 is valid.

You have assured that the door closer was not modified since the initial type test.

Therefore the validity of the test certificate no. 120002116.51-03 is extended up to June, 1st 2014.

Best regards
By order

Jansen



H. Jansen
Head of the test laboratory

Test Certificate No. 120002116.51-03

1st Copy

Contracting Party

Dorma GmbH & Co. KG
Breckerfelderstr. 42-48
D-58256 Ennepetal

Date of order:

06.02.2004

Date of test:

07.02.2004 to
04.01.2006

Assignment

Testing of controlled door closing devices (door closer) in accordance with DIN EN 1154: 1997-05 (Ref. No. EN 1154: 1996 D). The tests are to be including the additional requirements according to annex A of DIN EN 1154.

Description of Samples

Overhead door closer with hydraulic damping, second closing area and sliding rail
„Dorma TS 90 Impulse EN 3/4“

Description of the Test and Test Results

See test report No. 120002116.51-01.

Evaluation of the Test Results

The door closer “Dorma TS 90 Impulse EN 3/4” fulfil the requirements of the DIN EN 1154.

Door leaf fixing corresponding with appendix 1 and 2.

They are classified as follows in accordance with sec. 4 of DIN EN 1154:

| | | | | | |
|-----|---|--------|---|---|---|
| 3*) | 8 | 3 4 | 1 | 1 | 3 |
|-----|---|--------|---|---|---|

*) The opening angle of the door has to be limited to 150°.

Dortmund, January, 5th 2006

By order



Thorsten Meinks
Technischer Amtsinspektor



